

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

PV Switch-disconnector

Name and address of the applicant

ProJoy Electric Co., Ltd.
XinTang Industrial Zone, North-city Street,
PingJiang District, Suzhou 215000, P.R. China

Name and address of the manufacturer

ProJoy Electric Co., Ltd.
XinTang Industrial Zone, North-city Street,
PingJiang District, Suzhou 215000, P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui=1500V; Uimp=8kV; -40°C to +75°C; No polarity;
DC-PV2, DC-PV1/DC-21B; Ith/Ithe=32A;
IP66 (with enclosure, EL type);
Icw=1kA, 1s; Ue=800V/1000V/1200V DC; Ie=13A...32A;
(see Test item particulars and General product
information of Test Report for further ratings)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PEDSC100R-x32y-z, PEDSC120R-x32y-z
(x=PM, HM, DB, DC or EL; y=blank, R or L;
z=2, 4, 4T, 4B or 4S)
/see General product information of Test Report for
further details/

Additional information (if necessary may also be reported on page 2)


A sample of the product was tested and found to be in conformity with

IEC 60947-3:2008 + AMD1:2012 + AMD2:2015
IEC 60947-1:2007 + AMD1:2010 + AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

1W180281

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division MEE
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu



Date: 2018-06-26

Signature:

Gábor Kassai